

# Certificate of Compliance

Certificate Number 20090421- EX15399  
Report Reference EX15399, 2009 January 22  
Issue Date 2009 April 21

Page 1 of 1



*Issued to:* ELECTROSTEEL CASTINGS LTD  
NO 19 CAMAC ST, KOLKATA, WB 700017 INDIA.

*This is to certify that representative samples of*

## Ductile-Iron Pipe

Joint Type	Diam Size In.	PressureClass	ThknsClass
Push On Joint	4	350	51-56
	6, 8, 10, 12	350	50-56

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:* UL 194, "Gasketed Joints for Ductile-Iron and Gray-Iron Pressure Pipe and Fittings for Fire Protection Service."  
ANSI/AWWA C150/A21.50-02 and ANSI/AWWA C151/A21.51-02

*Additional Information:* Ductile-iron pipe is made with plain ends, bell and spigot, standardized mechanical, roll-on or other special types of joints formed from bell and plain-end pipe employing a circular rubber gasket as the only accessory for sealing purposes.  
This product has not been investigated for use in potable water systems.  
Authorities Having Jurisdiction should be consulted before installation.

## Look for the UL Listing Mark on the product

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Issued by: *Vidya Bhat*

Reviewed by: *Matthew D Tennenbaum*

**Vidya.Bhat, Customer Service Professional**

**Matthew D. Tennenbaum, Staff Engineer**

UL India Pvt. Ltd

UL Inc. Division Office

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc.  
For questions in India, you may call +91-80-4138 4400. UL India pvt. Ltd